

TAMIL NADU FIRE AND RESCUE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE

R.C.No.175/V/2020

Date: 12.06.2020

Licence No : 18

Sub : No Objection Certificate – Bhavan's Rajaji Vidyashram, No.6, Kilpauk Garden Road, Kilpauk, Chennai -600 010 – Regarding.

- Ref: (1) G.O.No.122, School Edu (2) Dpt. Date : 14.09.2004
(2) G.O.No.123, School Edu (2) Dpt. Date : 14.09.2004
(3) Your application letter, dated 09.06.2020

Based on the Govt. Order mentioned above and the requisition letter given by the **BHAVAN'S RAJAJI VIDYASHRAM at No.6, Kilpauk Garden Road, Kilpauk, Chennai -600 010 Tamil Nadu** the building and premises Comprises of Ground + 3 Floors Owned / Occupied by Bhavan's Rajaji Vidyasharam School have complied with the fire prevention and fire safety requirement in accordance with rule of State Fire Service Rules, and verified on 11.06.2020 in the presence of Mr.P.G.Subramanian, Principal and that the school is granted NOC for a period of ONE YEAR from 12.06.2020 to 11.06.2021 subject to the conditions stated below.

The above premises inspected by **P. CHIDAMBARAM**, Station Officer, Kilpauk, on **11.06.2020**.

CONDITIONS

1. This License is Valid for One Year from the date of issue.
2. Fire safety Systems should be maintained in good working conditions.
3. Mock drill to be conducted periodically with the help of local Fire Brigades.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per Sq.Metre as per the National Building Code-2005.
 - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c. As para 6.3 of the BIS Standards IS 14435-1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
 - d. Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e. Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Central District at Kilpauk.

To : **Mr. P.G. Subramanian**, Principal
BHAVAN'S RAJAJI VIDYASHRAM
No.6, Kilpauk Garden Road,
Kilpauk, Chennai -600 010


STATION OFFICER
FIRE AND RESCUE STATION
KILPAUK, CHENNAI-10

Copy: District Officer, Central District, Pudupet, Chennai – 600 002.